



Note: Watermain must be raised to provide a maximum of 7.0' of cover if C is greater than 10.0'

## FIGURE NO. 22

INSULATION REQUIREMENTS  
EXISTING WATER MAIN IN FILL SECTION



CITY OF NEW BERLIN  
ENGINEERING DEPARTMENT

DRAWN BY:  
NLH

DATE:  
6/18

SCALE:  
NTS